


INSTALLATION INSTRUCTIONS FOR OPTIMA® SYSTEMS SENSOR ACTIVATED SLOAN® and REGAL® CONCEALED and EXPOSED FLUSHOMETERS



Exposed Closet Flushometers 1-1/2" Top Spud

- Model 110/111 ES-S
- Model 115 ES-S
- Model 116 ES-S

Concealed Closet Flushometers 1-1/2" Exposed Back Spud

- Model 140 ES-S
- Model 153 ES-S
- Model 152 ES-S

Exposed Urinal Flushometers 1-1/4" Top Spud

- Model 180 ES-S
- Model 186 ES-S

Concealed Urinal Flushometers 1-1/4" Back Spud

- Model 190 ES-S
- Model 195 ES-S
- Model 192 ES-S
- Model 197 ES-S


LIMITED WARRANTY

Unless otherwise noted, Sloan Valve Company warrants this product, manufactured and sold for commercial or industrial uses, to be free from defects in material and workmanship for a period of three (3) years (one (1) year for special finishes, SF faucets, PWT electronics and 30 days for PWT software) from date of first purchase. During this period, Sloan Valve Company will, at its option, repair, replace, or refund the purchase price of any product which fails to conform with this warranty under normal use and service. This shall be the sole and exclusive remedy under this warranty. Products must be returned to Sloan Valve Company, at customer's cost. No claims will be allowed for labor, transportation or other costs. This warranty extends only to persons or organizations who purchase Sloan Valve Company's products directly from Sloan Valve Company for purpose of resale. This warranty does not cover the life of the batteries.


THERE ARE NO WARRANTIES WHICH EXTEND BEYOND THE DESCRIPTION ON THE FACE HEREOF. IN NO EVENT IS SLOAN VALVE COMPANY RESPONSIBLE FOR ANY CONSEQUENTIAL DAMAGES OF ANY MEASURE WHATSOEVER.

URINAL ROUGH-INS


MODEL 180 ES-S




MODEL 186 ES-S




MODEL 190 ES-S




MODEL 192 ES-S



MODEL 195 ES-S



MODEL 197 ES-S




SENSOR LOCATION & POSITIONING IS CRITICAL!


Failure to properly position the electrical boxes to the plumbing rough-in will result in improper installation and impair product performance. All tradesmen (plumbers, electricians, tile setters, etc.) involved with the installation of this product must coordinate their work to assure proper product installation.

WATER CLOSET ROUGH-INS


MODELS 110/111 ES-S




MODEL 152 ES-S




MODELS 115/116 ES-S



MODEL 153 ES-S



MODEL 140 ES-S



‡ POSITION OF SENSOR BOX CAN BE RAISED OR LOWERED 1" (25 mm) IF IN CONFLICT WITH HANDICAP GRAB BARS.

SENSOR LOCATION & POSITIONING IS CRITICAL!
 Failure to properly position the electrical boxes to the plumbing rough-in will result in improper installation and impair product performance. All tradesmen (plumbers, electricians, tile setters, etc.) involved with the installation of this product must coordinate their work to assure proper product installation.

PRIOR TO INSTALLATION

Prior to installing the sensor equipped flushometer, install the items listed below. Refer to Rough-ins on Page 1 and illustrations on this page.

- 2-gang electrical box — 4" x 4" x 2-1/2" (102 mm x 102 mm x 64 mm) for sensor; see paragraph entitled "Sensor Location"
- 2-gang electrical box — 4" x 4" x 2-1/2" (102 mm x 102 mm x 64 mm) for transformer; see paragraph entitled "Transformer Installation" (mount in a convenient location)
- Electrical wiring to the transformer box (120 VAC, 2 amp service required for each EL-154, 24 VAC, 50 VA transformer used)
- Urinal fixture
- Drain line
- Water supply line

IMPORTANT:

- **ALL ELECTRICAL WIRING IS TO BE INSTALLED IN ACCORDANCE WITH NATIONAL/LOCAL CODES AND REGULATIONS.**

- **ALL PLUMBING IS TO BE INSTALLED IN ACCORDANCE WITH APPLICABLE CODES AND REGULATIONS.**
- **WATER SUPPLY LINES MUST BE SIZED TO PROVIDE AN ADEQUATE VOLUME OF WATER FOR EACH FIXTURE.**
- **A 24 VAC STEP-DOWN TRANSFORMER MUST BE USED.**
- **USE APPROPRIATE PRECAUTIONS WHILE CONNECTING TRANSFORMER TO 120 VAC POWER SOURCE.**
- **FLUSH ALL WATER LINES PRIOR TO MAKING CONNECTIONS.**

Sloan's flushometers are designed to operate with 15 to 100 psi (104 to 689 kPa) of water pressure. **THE MINIMUM PRESSURE REQUIRED TO THE VALVE IS DETERMINED BY THE TYPE OF FIXTURE SELECTED.** Consult fixture manufacturer for minimum pressure requirements.


Most Low Consumption water closets (1.6 gallon/6.0 liter) require a minimum flowing pressure of 25 psi (172 kPa).

TRANSFORMER INSTALLATION

Install transformer (EL-154) on a 2-gang electrical box, 4" x 4" x 2-1/2" (102 mm x 102 mm x 64 mm) in a convenient location; refer to the illustration at right side of this page.

Note: One Sloan EL-154 transformer can operate up to ten Optima equipped flushometers. Run 18-gauge wire from transformer to flushometer(s). Wire supplied by others. **DO NOT** supply power to transformer until installation of flushometer is complete.

Note: A maximum of ten (10) flushometer units can operate from one (1) Sloan EL-154 transformer, Class 2, UL Listed, 50 VA (min.) at 24 VAC, plate mounted.



SENSOR LOCATION

Exposed closet models employ two (2) electrical boxes while concealed closet and exposed/concealed urinal models employ one (1) electrical box. Refer to rough-in illustrations for locations.

ELECTRICAL BOX LOCATION IS CRITICAL — Failure to properly position the electrical boxes to the plumbing rough-in will result in improper installation and impair product performance. All tradesmen (plumbers, electricians, tile setters, etc.) involved with the installation of this sensor activated flushometer must be familiar with the requirements of its installation. Improper installation may void the manufacturer's warranty.

Note: A template is packaged with Models 180 ES-S and 186 ES-S valves to properly position electrical boxes. Refer to rough-in illustrations for installation of electrical boxes.

Note: Use Appleton #4SD1 Electrical Box and #8470 Plaster Ring or equivalent.



Note: Install plaster ring so screw holes are on left and right side of box.

Note: Break tiles to allow screw holes in plaster to show.

TOOLS REQUIRED FOR INSTALLATION

- Slotted screwdriver
- 5/64" hex wrench (supplied)
- Wire stripper/crimping tool
- Sloan A-50 Super-Wrench™, Sloan A-109 Plier Wrench or smooth jawed spud wrench

ELECTRICAL BOX INSTALLATION DIAGRAM



!!! IMPORTANT !!!

WITH THE EXCEPTION OF CONTROL STOP INLET, DO NOT USE PIPE SEALANT OR PLUMBING GREASE ON ANY VALVE COMPONENT OR COUPLING!

!!! IMPORTANT !!!

PROTECT THE FINISH OF SLOAN'S FLUSHOMETERS — DO NOT USE TOOTHED TOOLS TO INSTALL OR SERVICE THESE VALVES. USE A Sloan A-50 Super-Wrench™, Sloan A-109 Plier Wrench OR SMOOTH JAWED SPUD WRENCH TO SECURE ALL COUPLINGS. ALSO SEE "CARE AND CLEANING" SECTION.

!!! IMPORTANT !!!

THIS PRODUCT CONTAINS MECHANICAL AND/OR ELECTRICAL COMPONENTS THAT ARE SUBJECT TO NORMAL WEAR. THESE COMPONENTS SHOULD BE CHECKED ON A REGULAR BASIS AND REPLACED AS NEEDED TO MAINTAIN THE VALVE'S PERFORMANCE.

If you have questions about how to install your Sloan flushometer, consult your local Sloan Representative or call Sloan Technical Support at:


1-888-SLOAN-14 (1-888-756-2614)

1 - INSTALL OPTIONAL SWEAT SOLDER ADAPTER (ONLY IF YOUR SUPPLY PIPE DOES NOT HAVE A MALE THREAD)

- Measure from finished wall to C/L of fixture spud. Cut pipe 1¼" (32 mm) shorter than this measurement. Chamfer O.D. and I.D. of water supply pipe.
- Slide threaded adapter fully onto pipe.
- Sweat solder the adapter to pipe.


!!! IMPORTANT !!!

WITH THE EXCEPTION OF THE CONTROL STOP INLET, DO NOT USE PIPE SEALANT OR PLUMBING GREASE ON ANY VALVE COMPONENT OR COUPLING!




2 - INSTALL COVER TUBE, WALL FLANGE AND CONTROL STOP TO SUPPLY PIPE

- A** Measure from finished wall to first thread of adapter or threaded supply pipe (dimension "X"). Cut cover tube to this length.
- B** Slide cover tube over pipe. Slide wall flange over cover tube until against wall.
- C** Thread control stop onto pipe. Tighten with a wrench.






- D** Tighten wall flange set screw with hex wrench supplied. **DO NOT** install vandal resistant stop cap at this time.



3 - INSTALL VACUUM BREAKER CONNECTION

- A** Assemble pipe, elbows, couplings, nylon slip gasket, rubber gaskets and flanges as illustrated.
- B** Insert tube into fixture spud.
- C** Hand tighten all couplings.



4 - INSTALL FLUSHOMETER

NOTE


For High Efficiency Urinal Flushometers (0.5, 0.25 and 0.125 gpf), it is necessary to first insert the flow control component into the tailpiece assembly. See the H1015A flow control kit and separate instructions for details on how to install.

- A** Lubricate tailpiece o-ring with water. Insert adjustable tailpiece into control stop. Tighten tailpiece coupling by hand.
- B** Align flushometer directly above the vacuum breaker flush connection by sliding the flushometer body IN or OUT as needed. Tighten vacuum breaker coupling by hand.
- C** Align flushometer body and securely tighten first the tailpiece coupling (1), then the vacuum breaker and pipe couplings (2), and finally the spud coupling (3). Use a wrench to tighten these couplings in the order shown.

NOTE

Max. adjustment of Sloan Adjustable Tailpiece is 1/2" (13 mm) IN or OUT from the standard 4 3/4" (121 mm) (c/l of Valve to c/l of Control Stop).

If roughing-in measurement exceeds 5 1/4" (133 mm), consult factory for longer tailpiece.




5 - CONNECT SOLENOID OPERATOR


- A** To ease installation, remove the solenoid operator from the flushometer; however, prior to removal, read and adhere to the following precautions.
 - When removing the coil from the solenoid plunger guide, do so only with the power **OFF**. Failure to turn power off can result in damage to the sensor, solenoid coil and transformer.
 - When removing the solenoid operator from the valve, take care not to damage the o-ring seal on the operator assembly.

- B EXPOSED MODELS ONLY** — Slide coil wires through tail (F-15) and screw tail into solenoid housing (EL-162-2).
- C EXPOSED MODELS ONLY** — Slide flange assembly (EL-431-A) and cover plate (EL-151) over tail, respectively.


EXPOSED URINAL FLUSHOMETERS



EXPOSED WATER CLOSET FLUSHOMETER



CONCEALED FLUSHOMETER




!!! IMPORTANT !!!

DO NOT REMOVE COIL FROM SOLENOID PLUNGER GUIDE UNLESS POWER HAS BEEN DISCONNECTED. FAILURE TO DO SO MAY DAMAGE SENSOR, COIL AND TRANSFORMER.


6 - ELECTRICAL HOOK-UP

- A** Be certain power is **OFF** to prevent damage to electrical components. Connect Sensor to Transformer and Solenoid coil EXACTLY as shown.
- B** Connect 24 volt source lead to terminal labeled "24 VAC IN" of Sensor.
- C** Connect solenoid lead to terminal labeled "TO VALVE" of Sensor.
- D** Connect remaining solenoid lead to remaining 24 volt source lead.


Wiring Diagram for One Flush Valve



Wiring Diagram for Multiple Flush Valves





WIRING DIAGRAM




7 - INSTALL SENSOR, YOKE, OVERRIDE BUTTON (IF APPLICABLE) AND COVER PLATE

- A** Install sensor (EL-1500-L) into the 2-gang electrical box using two (2) long screws provided. Ensure that sensor lens faces outward and horizontally from finished wall.
- B** Install inner nut, bracket and outer nut on threaded shaft of override button.
- C** Mount bracket to yoke.
- D** Adjust distance that override button will protrude through wall plate using nut on each side of bracket. Threaded shaft end of override Button should be flush with wall plate. Override button should be connected parallel to the EL-1500-L Sensor.
- E** Mount assembled yoke to electrical box.
- F** Install sensor cover plate and secure with tamper-proof screws (EL-152).




8A - INSTALL SENSOR COVER PLATE, SECURE SOLENOID HOUSING AND COIL ASSEMBLY (FOR EXPOSED URINAL MODELS ONLY)

- A** Install Sensor Cover Plate (EL-151, Exposed; EL-161, Concealed) and secure with Tamper-Proof Screws (EL-152), provided.



- B** Carefully install solenoid operator to flushometer while aligning tail assembly to cover plate. Wet o-ring seal of solenoid operator with water to lubricate. Secure solenoid operator to flushometer by tightening solenoid coupling. Slide solenoid flange assembly (EL-431-A) against sensor cover plate (EL-151) and tighten Setscrew to Tail (F-15).

Note: Hex key wrench services tamper-proof screws and setscrew. Tighten solenoid nut (EL-101).




8B - INSTALL SOLENOID COVER PLATE, SECURE SOLENOID HOUSING AND COIL ASSEMBLY (FOR EXPOSED WATER CLOSET MODELS ONLY)

- A** Install solenoid operator cover plate (HY-66) and secure with the tamper-proof screws (EL-152) provided.

- B** Slide solenoid flange assembly (EL-431-A) against cover plate (HY-66) and tighten setscrew to tail (F-15).



Note: Hex key wrench services tamper-proof screws and setscrew. Tighten solenoid Nut (EL-101).

- C** Carefully install solenoid operator to flushometer while aligning tail to solenoid cover plate. Wet o-ring seal of solenoid operator with water to lubricate. Secure solenoid operator to flushometer by tightening solenoid coupling. Slide solenoid flange assembly against solenoid cover plate and tighten set screw to tail.



9 - FLUSH OUT SUPPLY LINE

- A** Make sure control stop is CLOSED.
- B** Remove flushometer cover and lift out inside parts assembly. Install flushometer cover wrench tight.
- C** Open control stop. Turn on water supply to flush line of any debris or sediment.
- D** Shut off control stop, remove cover and reinstall Inside Parts Assembly. Install flushometer cover wrench tight. Do Not open Control Stop until **Step 12**.



10 - POWER AND START-UP MODE

NOTE: IT IS RECOMMENDED THAT ALL ELECTRONIC CONNECTIONS BE TESTED WITH THE WATER SUPPLY OFF.

- A** Turn power ON. The self-adaptive sensor automatically adapts to the surrounding environment when 24 volt supply is activated. No manual adjustments are required.
- B** Start-up mode will take approximately one (1) minute to complete its cycle and it's important that no non-permanent target is present at this time. A continuous red light visible in sensor window indicates sensor is in the start-up mode. If the red light is flashing, this indicates that the sensor is picking up a target. Unless this target is a permanent fixture in the sensor's environment (i.e., a wall or stall door), it must be removed from the view of the sensor. In this case, disconnect the 24 volt power supply for twenty (20) seconds or more. Reconnect the 24 volt power supply at the transformer or the fuse box. When the start-up cycle is complete, there will be no light visible in the sensor window.


NOTE: IF 24 VOLT POWER SUPPLY IS INTERRUPTED AT ANY TIME FOR MORE THAN FIFTEEN (15) SECONDS, THE START-UP MODE AUTOMATICALLY REPEATS ITSELF WHEN POWER IS RESTORED.

- C** Incorrect wiring or a short in the 24 volt power supply is indicated by a continuous warning signal seen in the sensor window. The visible red light flashes an "SOS" signal: three (3) short, three (3) long, three (3) short and continually repeats this signal, this indicates incorrect wiring or a short in the 24 volt power supply.


11 - DETECTION/ACTIVATION

- A** When an object is detected, a slowly flashing red light will appear in the sensor window. After approximately sixteen (16) seconds (closet), eight (8) seconds (urinal), the light will flash rapidly indicating sensor is armed and ready to activate solenoid when the object leaves the detection area. The solenoid will be activated within two (2) to four (4) seconds after non-detection.

EXPOSED URINAL FLUSHOMETER




EXPOSED WATER CLOSET AND CONCEALED FLUSHOMETERS



12 - TURN WATER ON AND ADJUST CONTROL STOP

- A** Adjust control stop to meet the flow rate required for proper cleansing of the fixture. Open control stop COUNTERCLOCKWISE 1/2 turn from the closed position.



- B** Activate flushometer by placing hand in front of sensor lens for ten (10) seconds and then moving it away.

- C** Adjust control stop after each flush until the rate of flow delivered properly cleanses the fixture.
- D** Install vandal resistant control stop cap onto control stop.


!!! IMPORTANT !!!

SLOAN'S FLUSHOMETERS ARE ENGINEERED FOR QUIET OPERATION. EXCESSIVE WATER FLOW CREATES NOISE, WHILE TOO LITTLE WATER FLOW MAY NOT SATISFY THE NEEDS OF THE FIXTURE. PROPER ADJUSTMENT IS MADE WHEN PLUMBING FIXTURE IS CLEANSED AFTER EACH FLUSH WITHOUT SPLASHING WATER OUT FROM THE LIP AND A QUIET FLUSHING CYCLE IS ACHIEVED.

NEVER OPEN CONTROL STOP TO WHERE THE FLOW FROM THE VALVE EXCEEDS THE FLOW CAPABILITY OF THE FIXTURE. IN THE EVENT OF A VALVE FAILURE, THE FIXTURE MUST BE ABLE TO ACCOMMODATE A CONTINUOUS FLOW FROM THE VALVE.

OPERATION


1. A continuous, invisible light beam is emitted from the sensor.
2. When a user enters the beam's effective range, water closets – 22" to 42" (559 mm to 1067 mm) and urinals – 15" to 30" (381 mm to 762 mm), the beam is reflected into the OPTIMA's scanning window and transformed into a low voltage electrical signal that activates a Sixteen-second time delay circuit. The time delay circuit eliminates false operation from passers-by in the rest room. Once the time delay is completed, the output circuit is alerted and continues in a "hold" mode for as long as the user remains within the effective range of the sensor.
3. When the user steps away from the sensor, the loss of reflected light initiates an electrical "one-time" signal that energizes the solenoid operator, and activates the Flushometer to flush the fixture. The circuit then automatically resets and is ready for the next user.



CARE AND CLEANING

DO NOT use abrasive or chemical cleaners (including chlorine bleach) to clean Flushometers as they may dull the luster and attack the chrome or special decorative finishes. Use **ONLY** soap and water, then wipe dry with clean cloth or towel.

While cleaning the bathroom tile, the Flushometer should be protected from any splattering of cleaner. Acids and cleaning fluids can discolor or remove chrome plating.



TROUBLESHOOTING GUIDE

NOTE: URINALS –When the sensor detects a user, a slow flashing red light appears in the sensor window. After eight (8) to ten (10) seconds, the light flashes rapidly to indicate that the sensor is armed. When the sensor no longer detects a user, the sensor immediately activates the solenoid valve after a 0.5 second delay. **WATER CLOSETS** – Detection and activation are the same as for the urinal except when the sensor no longer detects an user, the sensor activates the solenoid valve after a three (3) second delay.

1. VALVE DOES NOT FUNCTION (RED LIGHT DOES NOT FLASH WHEN USER STEPS IN FRONT OF SENSOR).

A. No power is being supplied to sensor. Ensure that the main power is turned “ON.” Check transformer, leads and connections. Repair or replace as necessary.

B. EL-1500 sensor is not operating. Replace EL-1500 sensor.

2. VALVE DOES NOT FUNCTION (RED LIGHT FLASHES WHEN USER STEPS IN FRONT OF SENSOR).

Red light stops flashing when user steps away and valve makes a “clicking” sound but does not flush.

A. No water is being supplied to the valve. Make certain that water supply is turned “ON” and the control stop is open.

B. EL-128-A cartridge is fouled or jammed. Turn electronic power to valve “OFF” (failure to do so could result in damage to the solenoid coil).

Remove the solenoid operator from the valve and remove the EL-128-A cartridge. Clean and/or repair as necessary.

The red light stops flashing when user steps away but the valve does NOT make a “clicking” sound and does NOT flush.

A. EL-163-A solenoid shaft assembly is fouled or jammed. Turn electronic power to valve “OFF” (failure to do so could result in damage to the solenoid coil). Remove EL-101 or EL-166 nut from the solenoid operator. Remove the coil from the solenoid operator. Use a spanner wrench or pliers to remove the EL-163-A solenoid shaft assembly from valve. Clean and/or replace as necessary. Be sure to replace plunger spring when reassembling solenoid shaft assembly.

The red light flashes three (3) short flashes, three (3) long flashes then three (3) short flashes (“S-O-S”) and continues to repeat this cycle even when user steps out of the sensor’s detection range.

A. EL-1500 sensor wiring connections are incorrect. Rewire sensor to valve. One solenoid lead connects to the “TO VALVE” connection on sensor. One transformer lead connects to the “24 VAC IN” connection on Sensor. Second solenoid lead and second transformer lead connect together.

B. Wiring to sensor is ground shorted. Find short in wiring circuit and correct.

C. EL-165-2 solenoid coil is burnt out or coil is not connected to solenoid plunger shaft. Reinstall or replace coil as necessary.

3. VOLUME OF WATER IS INSUFFICIENT TO ADEQUATELY SIPHON FIXTURE.

A. Control stop is not open wide enough. Adjust control stop for desired water delivery.

B. Low consumption unit is installed on water saver or conventional fixture. Replace diaphragm component parts of valve with kit that corresponds to appropriate flush volume of fixture.

C. Inadequate water volume or pressure available from supply. Increase pressure or supply (flow rate) to the valve. Consult factory for assistance.

4. LENGTH OF FLUSH IS TOO LONG (LONG FLUSHING) OR VALVE FAILS TO SHUT OFF.

A. Water saver valve is installed on low consumption fixture. Replace diaphragm component parts of valve with kit that corresponds to appropriate flush volume of fixture.

B. Relief valve in diaphragm is not seated properly or bypass hole in diaphragm is clogged. Disassemble inside diaphragm component parts and wash parts thoroughly. Replace worn parts if necessary.

5. WATER SPLASHES FROM FIXTURE.

A. Supply flow rate is more than necessary. Adjust control stop to meet flow rate required for proper cleansing of the fixture.

B. Closet valve is installed on urinal fixture. Replace closet diaphragm component parts with proper kit (inside diaphragm assembly or inside parts kit).

**When further assistance is required,
please contact the Sloan Technical Support at:
+1.888.SLOAN.14 (+1.888.756.2614)
or visit us online at:
www.sloan.com**



!!! IMPORTANT !!!

WITH THE EXCEPTION OF THE CONTROL STOP INLET, DO NOT USE PIPE SEALANT OR PLUMBING GREASE ON ANY VALVE COMPONENT OR COUPLING!

!!! IMPORTANT – Control Stop Setting !!!

NEVER OPEN CONTROL STOP TO WHERE THE FLOW FROM THE VALVE EXCEEDS THE FLOW CAPABILITY OF THE FIXTURE. IN THE EVENT OF A VALVE FAILURE, THE FIXTURE MUST BE ABLE TO ACCOMMODATE A CONTINUOUS FLOW FROM THE VALVE.

URINAL PARTS LIST





Item No.	Part No.	Description
1	‡	Solenoid Operated Valve Assembly
2	H-700-A ‡	1" (25 mm) Bak-Chek® Control Stop
	H-700-A ‡	¾" (20 mm) Bak-Chek® Control Stop
3A	V-600-AA	1¼" (32 mm) x 9" (229 mm) Vacuum Breaker Assembly CP (Model 180)
3B	V-600-AA	¾" (20 mm) x 9" (229 mm) Vacuum Breaker Assembly CP (Model 186)
3C	V-500-AA	1½" (38 mm) x 11½" (292 mm) Vacuum Breaker Assembly RB (Model 190)
3D	V-500-AA	¾" (19 mm) x 10½" (267 mm) Vacuum Breaker Assembly RB (Models 195/197)
3E	V-500-AA	1½" (38 mm) x 7½" (191 mm) Vacuum Breaker Assembly RB (Model 192)
4A	F-5-A	1¼" (32 mm) Spud Coupling Assembly (Model 180)
4B	F-5-A	¾" (19 mm) Spud Coupling Assembly (Model 186)
5	F-15-A	ELL with ¾" (19 mm) Tail (Models 195/197)
6	F-2-AW	¾" (19 mm) Slip Joint Coupling (Models 195/197)
7	F-21	Double Slip Elbow (Models 190/192)

Item No.	Part No.	Description
8	F-2A	1½" (38 mm) Slip Joint Coupling (Model 190)
9	F-2A	Coupling with S-21 Gasket
10	F-110	1¼" (32 mm) O.D. Outlet
11	F-2-A-U	1¼" (32 mm) Slip Joint Coupling
12	F-2-AA	1½" (38 mm) Slip Joint Coupling (Set of Two) (Model 192)
13	F-102	1½" Outlet Tube CP
14	F-7	Flange
15	F-25-A	1¼" Elbow Assembly
16	F-15-A	ELL with ¾" Tail CP (Model 197)
17	F-5-A	1¼" Spud Coupling Assembly CP
18	F-5-A	¾" Spud Coupling Assembly CP
19	F-15	Tail Assembly
20	EL-431-A	Flange Assembly
21A	EL-151	Cover Plate (Models 180/186)
21B	EL-161	Cover Plate (Models 190/192/195/197)
22	EL-152	Screw (4 Required)
23	EL-168-A	Yoke Assembly
24	EL-1500	Urinal Sensor

‡ Part number varies with valve model variation; consult factory.

WATER CLOSET PARTS LIST



Item No.	Part No.	Description
1	‡	Solenoid Operated Valve Assembly
2	H-700-A ‡	Bak-Chek® Control Stop
3A	V-600-A ‡	1½" (38 mm) Vacuum Breaker Assembly CP (Models 110/111/115/116)
3B	V-500-A	1½" (38 mm) x 11½" (292 mm) Vacuum Breaker Assembly RB (Models 140/152)
3C	V-500-A	1½" (38 mm) x 6" (152 mm) Vacuum Breaker Assembly RB (Model 153)
4	F-5-A	1½" (38 mm) Spud Coupling Assembly CP
5	F-21	1½" (38 mm) Double Slip Elbow
6	F-2-AA	1½" (38 mm) Slip Joint Coupling (Set of Two)
7	F-102	1½" (38 mm) Outlet Tube CP

Item No.	Part No.	Description
8	F-7	Flange
9	F-25-A	1½" (38 mm) Elbow Assembly
10	F-2-A	Coupling with S-21 Gasket
11	F-102	1½" (38 mm) Outlet Tube CP
12	F-15	Tail Assembly
13	EL-431-A	Flange Assembly
14	HY-66	Cover Plate
15	EL-201	Cover Plate
16	EL-152	Screw (4 Required per Plate)
17	EL-141-A	Yoke and Override Button Assembly
18	EL-1500-L	Closet Sensor

‡ Part number varies with valve model variation; consult factory.

The information contained in this document is subject to change without notice.

SLOAN • 10500 SEYMOUR AVENUE • FRANKLIN PARK, IL 60131

Phone: +1.800.982.5839 or +1.847.671.4300 • Fax: +1.800.447.8329 or +1.847.671.4380 • www.sloan.com